

FIRE SAFETY CERTIFICATE

APPENDIX XII


NO: 126 /2025
R.C.NO: 372 / V /2025

DATE: 22.04.2025

Certified that the MAHATMA GANDHI CENTERNARY VIDYALAYA at T.S.NO.53, WARD-E, BLOCK-26, TENNUR HIGH ROAD, TIRUCHIRAPPALLI- 620017, TAMILNADU Comprised of MAIN BLOCK (GROUND FLOOR, FIRSTFLOOR, SECOND FLOOR & THIRD FLOOR) Owned by MAHATMA GANDHI CENTERNARY VIDYALAYA have complied with the fire prevention and the fire safety requirements in accordance with rule of state Fire Service, and verified by P. SATHYAVARTHANAN,B.SC.,B.L., ASSISTANT DISTRICT OFFICER, on 22.04.2025 in the presence of PRINCIPAL, MAHATMA GANDHI CENTERNARY VIDYALAYA And that the building is fits for occupancy up to classes I TO X With effect from 22.04.2025 for a period of ONE YEAR in accordance with rule and subject to compliance of specific conditions as appended:-

CONDITIONS

- (i) SHOULD NOT EXCEED 2612 NO OF STUDENTS
- (ii) AS PER NATIONAL BUILDING CODE 2016 ALL PASSIVE MEASURES SHOULD BE FOLLOWED.
- (iii) NO CHANGES SHOULD BE MADE TO THE SETTINGS IN THE APPROVED PLAN.
- (vi) AS PER NATIONAL BUILDING CODE 2016 ALL FIRE FIGHTING EQUIPMENTS SHOULD BE INSTALLED AND MAINTAIN PROPERLY. SHOULD BE DESIGNATE A PERSON RESPONSIBLE FOR FIRE AND LIFE SAFETY. SHOULD BE CONDUCT BASIC FIRE FIGHTING AND EVACUATION DRILL AND FIRE MOCK DRILL ONCE IN THREE MONTHS.



Signature with Seal

Name: P. SATHYAVARTHANAN, B.SC., B.L.,

Designation: ASSISTANT DISTRICT OFFICER,

Name & Address of Department/Office: TAMIL NADU FIRE AND RESCUE SERVICE,
TIRUCHIRAPPALLI STATION.



TO:

THE PRINCIPAL,
MAHATMA GANDHI CENTERNARY VIDYALAYA,
T.S.NO.53, WARD-E, BLOCK-26,
TENNUR HIGH ROAD,
TIRUCHIRAPPALLI- 620017, TAMILNADU.

COPY TO: DISTRICT OFFICER, TAMIL NADU FIRE AND RESCUE SERVICE,
TIRUCHIRAPPALLI DISTRICT.